

APPENDICES (Part of this document):

2015 Asbestos Information Sheets for Locations confirmed as containing / presumed to contain ACM's.

2020 Survey Photographs showing locations confirmed in 2015 survey as containing / presumed to contain ACM's.

Alston Site Map

REFERENCES: (Available in STRPS H & S Documentation Records)

Targeted Asbestos Pre-Refurbishment Survey Report for South Tynedale Railway Alston
Dated 20.07.2015.

INDG 223 Rev 5 - Managing Asbestos in Buildings HSE April 2012

HSE EM9 – Dated 09/17 Disposal of Asbestos Waste

SOUTH TYNEDALE RAILWAY



Asbestos Information		Inspection Number:	NST02
Site Reference	Zer/st/ry/2015	Client Name	South Tynedale Railway
Address		South Tynedale Railway, Alston, CA9 3JB	
Level/Floor	Ground		
Room/Area	Various Areas		
Element	Older Machinery		
Inspection Method	No Sample Taken		
Inspection Date	17 th July 2015		
Material Assessment			
Product Type	Non Friable Material		
Extent of Damage	Good Condition		
Surface Treatment	Cement/Enclosed Spray or Lagging/Sealed Board		
Overall Asbestos Type	Chrysotile (Presumed)		
Material Assessment	3.0		
Priority Assessment			
Occupant Activity	Rare Disturbance		
Disturbance (Accessibility)	Normally Inaccessible		
Disturbance (Extent)	Small amounts or Items		
Disturbance (Location)	Large Rooms/Well Ventilated		
Exposure (Usage Time)	Less than 1 hour		
Exposure (Freq. of Use)	Infrequent		
Exposure (No. of Occupants)	None		
Maintenance (Freq. Of)	Less Than Once per Year		
Maintenance (Type Of)	Low Disturbance		
Priority Assessment	2.0		
Total Risk Assessment		Recommendation:	Remove if impacted by refurbishments
Score	5.0	Score Category	Very Low Risk



Older machinery may contain asbestos in the form of gaskets

2015 Asbestos Survey
 Ref: NST 01
 Location Ref:AS09
 Location:
 General View
 Old Electrical Switchgear

SOUTH TYNEDALE RAILWAY



Asbestos Information		Inspection Number:	NST02
Site Reference	Zer/st/ry/2015	Client Name	South Tynedale Railway
Address	South Tynedale Railway, Alston, CA9 3JB		
Level/Floor	Ground		
Room/Area	Various Areas		
Element	Older Machinery		
Inspection Method	No Sample Taken		
Inspection Date	17 th July 2015		
Material Assessment			
Product Type	Non Friable Material		
Extent of Damage	Good Condition		
Surface Treatment	Cement/Enclosed Spray or Lagging/Sealed Board		
Overall Asbestos Type	Chrysotile (Presumed)		
Material Assessment	3.0		
Priority Assessment			
Occupant Activity	Rare Disturbance		
Disturbance (Accessibility)	Normally Inaccessible		
Disturbance (Extent)	Small amounts or Items		
Disturbance (Location)	Large Rooms/Well Ventilated		
Exposure (Usage Time)	Less than 1 hour		
Exposure (Freq. of Use)	Infrequent		
Exposure (No. of Occupants)	None		
Maintenance (Freq. Of)	Less Than Once per Year		
Maintenance (Type Of)	Low Disturbance		
Priority Assessment	2.0		
Total Risk Assessment		Recommendation:	Remove if impacted by refurbishments
Score	5.0	Score Category	Very Low Risk



Older machinery may contain asbestos in the form of gaskets

2015 Asbestos Survey
 Ref: NST 02
 Location Ref: AS09
 Location:
 General View of
 Old Machinery